




CAUTION: Wear approved protective gloves and eye protection.
 This information is not intended to be a substitute for or to supplement any training in the safe handling and use of propane and related equipment, as required by any applicable law. Only individuals properly trained in the safe handling and use of propane and related equipment should be permitted to do so.



Right and Wrong Way of Hose Installation




Do not use excessive lengths of hose. Bends below the design bend radii weaken the hose by distorting the wire braid




The movement shown in the incorrect side view exerts torsion on the end fittings.




Obtain direct routing of the hose through the use of 90° and 135° Elbow fitting. Improve performance by using less hose and greater bend radius.




Do not fit hose assembly in twisted condition. This puts tension on the hose and reduces the working life of the assembly. Provide slack or bend in the hose to allow for changes in length that will occur when pressure is applied



Sharp bends can be avoided by using elbow fittings instead of straights. Avoid the use of bends in hose too close to the fittings.



HOSE INSTALLATION



1. Place socket in vice as shown. Squirt end of hose with lubricant and screw counterclockwise into socket until hose bottoms. Back off 1/2 turn.




2. Lubricate the threads of the nipple for adequate lubrication.



3. Place nipple head in vice. Screw hose and socket clockwise onto nipple until large threads engage.



4. Position socket in vice as shown and complete assembly.



ALL NPT CONNECTIONS
REQUIRE THREAD SEAL

FLARE CONNECTIONS DO
NOT REQUIRE THREAD SEAL

ALL CONNECTIONS
REQUIRE LEAK TEST
AFTER ASSEMBLY



<p>P/N: BRACKET OR RECEPTACLE QTY: 1</p> 	<p>P/N: PR-6 LOCATION: HRL9 QTY: CUT TO LENGTH</p> 	<p>P/N: PR-8 LOCATION: HRL1 QTY: CUT TO LENGTH</p> 
<p>P/N: PV2080 LOCATION: R3S1B17 QTY: 1</p> 	<p>P/N: MEJ400 LOCATION: GBS4B2 QTY: 1</p> 	<p>P/N: 116-4 LOCATION: GBS3B6 QTY: 2</p> 
<p>P/N: 48-64 LOCATION: GBS3B10 QTY: 2</p> 	<p>P/N: NF-ME229 LOCATION: R2S2B4 QTY: 1</p> 	<p>P/N: 2501-08-12F LOCATION: GBS5B3 QTY: 1</p> 
<p>P/N: 4401-8 LOCATION: GBS3B14 QTY: 2</p> 	<p>P/N: 4401-6 LOCATION: GBS3B3 QTY: 2</p> 	<p>INSTRUCTIONS</p> 